

LIGHTING

07.A GENERAL

07.A.01 While work is in progress, offices, facilities, accessways, working areas, construction roads, etc., shall be lighted by at least the minimum light intensities specified in Table 7-1.

07.A.02 Means of egress.

- a. Means of egress shall be illuminated, with emergency and non-emergency lighting, to provide a minimum of 11 lux (lx) (1 footcandle (lm/ft²)), measured at the floor. > **Reference NFPA 101**
- b. The illumination shall be arranged so that the failure of any single lighting unit, including the burning out of an electric bulb, will not leave any area in total darkness.

[Table 7-1: Minimum Lighting Requirements](#)

SECTION 8